

VOC Content Test Certificate

Tuesday 18th February 2020

Supplier: Husqvarna (4 Pioneer Ave, Tuggerah NSW 2259, Australia)

Sample Description: Husqvarna HiPERHARD(L)

Date Tested: February 2020 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3690-05 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960 as detailed for paints as well as South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

| | |
|--|---|
| Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B | Husqvarna HiPERHARD(L) |
| General Purpose adhesives and sealants: 50 grams per Litre | 37 grams per Litre as VOC content per material |
| <p><i>We hereby certify that Husqvarna HiPERHARD(L) is below the VOC Content limits of chosen categories specified by Green Star Design, Green Building Council of Australia</i></p> | |



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Luke Morley
BSc (Tech)
Consultant

V2002030